

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/FSDA/2023-24

Dated 08/06/2023

It is certified that an inspection team headed by KANCHAN LATA TIWARI..... FOOD SAFETY OFFICER
(Name of Officers with designation) from FOOD SAFETY AND DRUG ADMINISTRATION
(FSDA)
(Name of Department / Office) inspected the BABA GURUKUL ACADEMY
GURUKUL NAGAR BEARIH ROAD BARABANKI..... (Name & Address of the
school) on 07/06/2023..... (Date of Inspection) and found that the
BABA GURUKUL ACADEMY..... (Name of School) has save drinking water facilities for the
students and members of staff of the institution and is maintaining the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central / State /
U.T. Govt.

The Above is valid for a period of 5 year.....

Signature with Seal : Kanchan Lata Tiwari
08/06/2023
FOOD SAFETY OFFICER
BARABANKI

Name : KANCHAN LATA TIWARI.....

Designation : FOOD SAFETY OFFICER.....

Name & Address

of the Office / Department : FSDA BARABANKI.....

To

BABA GURUKUL ACADEMY
GURUKUL NAGAR BEARIH
ROAD BARABANKI.....

(Name & Address of the institution)

Principal
Baba Gurukul Academy
Barabanki

Manager
BABA GURUKUL ACADEMY
Gram - Sultanpur Post - Shahabpur
Distt. - Barabanki



ITS TESTING LABORATORY (P) LTD.

Laboratory: A-114, Sector-80, Phase-II, Noida, Gautam Budh Nagar - 201305, (U.P.)
An ISO 9001: 2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory
Website: www.itslab.in, Email: itslaboratorypvtltd@gmail.com, info@itslab.in,
contact@itslab.in, itrlclab@gmail.com
+91 9911659800, 93505780312, 09958849764, 07210888634



TC-11181

Report Code: W-030623-04, Page 1 of 2

TEST REPORT

Water Sample Analysis

Report Code: W-030623-04

Issue Date: 05/06/2023

Issued To: M/S. BABA GURUKUL ACADEMY
GURUKUL NAGAR BEHRICH ROAD BARABANKI (U.P) INDIA

SAMPLING & ANALYSIS DATA

Sample Description : Drinking Water Sample
Sample Drawn On : 02/06/2023
Sample Drawn By : Mr. Ashutosh Singh (ITS) Representative
Sampling Plan & Procedure : IS:3025 (Part-1) & APHA 23rd Edition
Sample Quantity : 1.0 Liter in Pet Bottle & 500ml in Sterilized Glass Bottle
Weather Condition : Clear
Sample Received On : 03/06/2023
Analysis Duration : 03/06/2023 To 05/06/2023

TEST RESULTS

Essential test as per IS:10500-2012

S. No.	Parameter	Test Method	Results	Units	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH	IS:3025(Part-11)	6.74	-	6.5 - 8.5	-
2.	Colour	IS:3025(Part-4)	<5.0	Hazen	5	15
3.	Turbidity	IS:3025(Part-10)	<1.0	NTU	1	5
4.	Total Hardness (as CaCO ₃)	IS:3025(Part-21)	16.0	mg/l	200	600
5.	Chloride(as Cl)	IS:3025(Part-32)	24.0	mg/l	250	1000
6.	Calcium (as Ca)	IS: 3025 (P- 40)	3.2	mg/l	75	200
7.	Iron (as Fe)	IS:3025(Part-53)	<0.05	mg/l	1.0	-
8.	Nitrate (as NO ₃)	IS: 3025 (P- 34)	<1.0	mg/l	45	No Relaxation
9.	Total Dissolved Solid	IS:3025(Part-16)	90.0	mg/l	500	2000
10.	Alkalinity (as Ca CO ₃)	IS: 3025 (P- 23)	19.0	mg/l	200	600
11.	Fluoride (as F)	APHA 22nd edit	<0.1	mg/l	1.0	1.5
12.	Sulphate (as SO ₄)	IS:3025 (P-24)	<1.0	mg/l	200	400
13.	Magnesium (as Mg)	IS:3025 (P-46)	3.69	mg/l	30	100

CHECKED BY

Principal
Principal
Baba Gurukul Academy
Barabanki



AUTHORIZED SIGNATORY

Manager
Manager
BABA GURUKUL ACADEMY
Gram - Sultanpur Post - Shahabpur
Distt. - Barabanki

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will be destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.



ITS TESTING LABORATORY (P) LTD.

Laboratory: A-114, Sector-80, Phase-II, Noida, Gautam Budh Nagar - 201305, (U.P.)
An ISO 9001: 2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory
Website: www.itslab.in, Email: itslaboratorypvtltd@gmail.com, info@itslab.in,
contact@itslab.in, itrlclab@gmail.com
+91 9911659800, 93505780312, 09958849764, 07210888634

Report Code: W-050023-04, Page 2 of 2

SENSARY REQUIREMENT

RESULTS				
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	Odour	IS:3025(Part-5)	Agreeable	Should be agreeable
2.	Taste	IS:3025(Part-8)	Agreeable	Should be agreeable

MICROBIOLOGICAL REQUIREMENT

RESULTS				
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	<i>Escherichia coli</i>	IS-1622:1981	Absent	Absent/100ml
2.	<i>Coliform Bacteria</i>	IS-1622:1981	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meet as per IS-10500:2012 in acceptable limit. Hence water is fit for Drinking purpose.

Mele
CHECKED BY

M.S.
AUTHORIZED SIGNATORY

[Signature]
Principal
Baba Gurukul Academy
Barabanki

[Signature]
Manager
BABA GURUKUL ACADEMY
Gram - Sultanpur Post - Shahabpur
Distt. - Barabanki

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.